

January 31, 2025

CAO Paul Laperriere and Council  
The Corporation of the Town of Mattawa  
160 Water Street, P.O. Box 390,  
Mattawa, ON P0H 1V0

**Re: 2024 Annual/Summary Report for the Mattawa Drinking Water System**

Dear Paul Laperriere and Council:

Ontario's Drinking-Water Systems Regulation (O. Reg. 170/03), made under the *Safe Drinking Water Act in 2002*, requires that the owner of a drinking water system prepare an Annual Report and an Annual Summary Report of the operation of the system and the quality of its water.

Annual Report

The annual report must cover the period of January 1<sup>st</sup> to December 31<sup>st</sup> in a year and must be prepared not later than February 28<sup>th</sup> of the following year. Pursuant to the legislative requirements, enclosed for your records is the 2024 Annual Report for the Mattawa Drinking Water System.

In accordance with Section 11 (6), the annual report must:

- (a) contain a brief description of the drinking-water system, including a list of water treatment chemicals used by the system during the period covered by the report;
- (b) summarize any reports made to the Ministry under subsection 18 (1) of the Act or section 16-4 of Schedule 16 during the period covered by the report;
- (c) summarize the results of tests required under the Regulation, or an approval or order, including an OWRA order, during the period covered by the report and, if tests required under this Regulation in respect of a parameter were not required during that period, summarize the most recent results of tests of that parameter;
- (d) describe any corrective actions taken under Schedule 17 or 18 during the period covered by the report;
- (e) describe any major expenses incurred during the period covered by the report to install, repair or replace required equipment; and
- (f) if the case of a large municipal residential system or a small municipal residential system, include a statement of where a report prepared under Schedule 22 will be available for inspection under subsection 12 (4) O. Reg. 170/03, s. 11 (6).

In addition, Section 11 (7) gives the direction that a copy of an annual report for the system is given, without charge, to every person who requests a copy and be made available for inspection by any member of the public during normal business hours. The reports should be made available at the office of the Town, or at a location that is accessible to the users of the water system.

### Summary Report

The annual summary report must cover the period of January 1<sup>st</sup> to December 31<sup>st</sup> in a year and must be prepared not later than March 31<sup>st</sup> of the following year. Pursuant to the legislative requirements, enclosed for your records is the 2024 Annual Summary for the Mattawa Drinking Water System.

As required in *Schedule 22, Summary Reports for Municipalities*, the annual summary must:

- (2) (a) list the requirements of the Act, the regulations, the system's approval, drinking water works permit, municipal drinking water licence, and any orders applicable to the system that were not met at any time during the period covered by the report; and  
  
(b) for each requirement referred to in clause (a) that was not met, specify the duration of the failure and the measures that were taken to correct the failure.
- (3) The report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system:
  1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average and maximum daily flows.
  2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system's approval, drinking water works permit or municipal drinking water licence, or if the system is receiving all of its water from another system under an agreement pursuant to subsection 5 (4), to the flow rates specified in the written agreement.

In addition, Section 12 (1) – 4 – gives the direction that a copy of the annual summary for the system is given, without charge, to every person who requests a copy and be made available for inspection by any member of the public during normal business hours. The reports should be made available at the office of the Town, or at a location that is accessible to the users of the water system.

These reports were prepared by the Ontario Clean Water Agency on behalf of the Town of Mattawa and are based on information kept on record by OCWA at the Mattawa WTP. The reports cover the period January 1<sup>st</sup> to December 31<sup>st</sup> 2024.

Please note that any Provincial Officers Orders or non-compliance issues that you have received directly from the MOE should be reviewed. Where non-compliance with the Order or Issue is evident and it is not included in the attached 2024 Annual/Summary Report, then we recommend that this information be added to the report.

After your review and inclusion of any additional information, this report is to be provided to the Council members representing the Town of Mattawa before March 31, 2025. Please ensure this distribution.

Yours truly,  
Ontario Clean Water Agency

Monique Malette  
Process and Compliance Technician

Copy to: Lori Duquette, Drinking Water Inspector, Ministry of the Environment, Conservation and Parks.



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

Mattawa Drinking Water System

# 2024 ANNUAL/SUMMARY REPORT

Prepared by the Ontario Clean Water Agency  
on behalf of the Corporation of the Town of Mattawa

## Table of Contents

<b>INTRODUCTION .....</b>	<b>2</b>
<b>Section 11 - ANNUAL REPORT .....</b>	<b>3</b>
1.0 Introduction .....	3
2.0 Mattawa Drinking Water System (DWS No. 210001905) .....	4
3.0 List of Water Treatment Chemicals Used Over the Reporting Period .....	5
4.0 Significant Expenses Incurred in the Drinking Water System .....	5
5.0 Drinking Water System Highlights .....	5
6.0 Details on Notices of Adverse Test Results and Other Problems Reported to & Submitted to the Spills Action Center .....	6
7.0 Microbiological Testing Performed During the Reporting Period .....	6
8.0 Operational Testing Performed During the Reporting Period .....	6
<b>Schedule 22 - SUMMARY REPORTS FOR MUNICIPALITIES .....</b>	<b>12</b>
1.0 Introduction .....	12
2.0 Requirements the System Failed to Meet .....	12
3.0 Summary of Quantities and Flow Rates .....	12
<b>CONCLUSION.....</b>	<b>15</b>

## List of Appendices

**APPENDIX A – Monthly Summary of Microbiological Test Results**

**APPENDIX B – Monthly Summary of Operational Data**

## **INTRODUCTION**

Municipalities throughout Ontario have been required to comply with Ontario Regulation 170/03 made under the Safe Drinking Water Act (SDWA) since June 2003. The Act was enacted following recommendations made by Commissioner O'Conner after the Walkerton Inquiry. The Act's purpose is to protect human health through the control and regulation of drinking water systems. O. Reg. 170/03 regulates drinking water testing, use of licensed laboratories, treatment requirements and reporting requirements.

Section 11 of Regulation 170/03 requires the owner to produce an Annual Report. This report must include the following:

1. Description of system & chemical(s) used
2. Summary of any adverse water quality reports and corrective actions
3. Summary of all required testing
4. Description of any major expenses incurred to install, repair or replace equipment

This annual report must be completed by February 28th of each year.

Section 22 of the regulation also requires a Summary Report which must be presented & accepted by Council by March 31<sup>st</sup> of each year for the preceding calendar year.

The report must list the requirements of the Act, its regulations, the system's Drinking Water Works Permit (DWWP), Municipal Drinking Water Licence (MDWL), Certificate of Approval (if applicable), and any Provincial Officer Order the system failed to meet during the reporting period. The report must also specify the duration of the failure, and for each failure referred to, describe the measures that were taken to correct the failure.

The Safe Drinking Water Act (2002) and the drinking water regulations can be viewed at the following website: <http://www.e-laws.gov.on.ca>.

To enable the Owner to assess the rated capacity of their system to meet existing and future planned water uses, the following information is also required in the report.

1. A summary of the quantities and flow rates of water supplied during the reporting period, including the monthly average and the maximum daily flows,
2. A comparison of the summary to the rated capacity and flow rates approved in the systems approval, drinking water works permit or municipal drinking water licence or a written agreement if the system is receiving all its water from another system under an agreement.

The reports have been prepared by the Ontario Clean Water Agency (OCWA) on behalf of the Owner and presented to council as the 2024 Annual/Summary Report.

## Section 11 - ANNUAL REPORT

---

### 1.0 Introduction

**Drinking-Water System Name:** MATTAWA DRINKING WATER SYSTEM  
**Drinking-Water System No.:** 210001905  
**Drinking-Water System Owner:** The Corporation of the Town of Mattawa  
**Drinking-Water System Category:** Large Municipal, Residential System  
**Period being reported:** January 1, 2024 to December 31, 2024

**Does your Drinking Water System serve more than 10,000 people?** No

**Is your annual report available to the public at no charge on a web site on the Internet?** Yes

**Location where Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.**

Town Hall at 160 Water Street and on the Municipal website at [www.mattawa.ca](http://www.mattawa.ca)

### ***Drinking Water Systems that receive drinking water from the Mattawa Drinking Water System***

The Mattawa Drinking Water System (DWS) provides all drinking water to the community of Mattawa.

### ***The Annual Report was not provided to any other Drinking Water System Owners.***

The Ontario Clean Water Agency prepared the 2024 Annual/Summary Report for the Mattawa DWS and provided a copy to the system owner; the Town of Mattawa. The Mattawa DWS is a stand-alone system that does not receive water from or send water to another system.

### ***Notification to system users that the Annual Report is available for viewing is accomplished through:***

- A public access notice via the web and a public access notice via Town Office.
- System analysis and reports available in the water System Information Binder available for the public to review at the Town Office.



Mattawa Drinking Water System

Section 11

# 2024 ANNUAL REPORT



## **2.0 Mattawa Drinking Water System (DWS No. 210001905)**

The Mattawa DWS is owned by the Corporation of the Town of Mattawa and consists of a Class II Distribution and Supply System. The Ontario Clean Water Agency (OCWA) is designated the Overall Responsible Operator for both the water supply and water distribution facilities.

### ***Raw Water Supply***

The water supply system for the Town of Mattawa consists of Well No. 1, Well No. 2, and an in-ground water storage reservoir that floats on the distribution system. These two groundwater supply wells, as well as the reservoir, provide drinking water to the residents of Mattawa. In accordance with the Municipal Drinking Water Licence, the drinking water system shall not be operated to exceed 6,540 cubic meters per day (m<sup>3</sup>/d).

Wells No. 1 and No. 2 are located inside a single structure situated at 400 Bissett Street in the Town of Mattawa. This facility houses two well pumps, an ultraviolet (UV) disinfection system, a sodium hypochlorite disinfection system, all control, monitoring, and alarm systems, as well as a standby diesel generator.

The wells are operated by OCWA and are utilized on a duty/standby basis. Well No. 1 is operated as the duty well from 6 am to midnight. Well No. 2 is used as the duty well from midnight to 6 am, for energy conservation purposes. The switchover of duty wells is automatically done via a timer within the plant programmable logic controller (PLC).

Well No. 1 is equipped with a vertical turbine pump capable of delivering 53.0 L/s at 105.8 m of total dynamic head. Well No. 2 has a vertical turbine pump rated at 22.7 L/s with a total dynamic head of 91.5 m. Recently variable frequency drive (VFD) installed for Well #2.

### ***Water Treatment***

Primary disinfection equipment includes two UV disinfection systems, each designed to deliver the required UV dosage at the rated capacity of the facility. Chlorination equipment includes a 200 L sodium hypochlorite (NaOCl) storage tank and dual chemical feed pumps that inject liquid chlorine into the system. Output from Well No. 1 and No. 2 is governed by system demand (water level in the reservoir). As the water level in the reservoir drops to the low water level (LWL), the selected duty well pump automatically starts.

The well pumps, UV disinfection system, sodium hypochlorite injection system, and analyzers are all supervised locally via the PLC. All alarms are instantly transmitted from the PLC to the alarm panel, which dials a security company and pages the Operator-on-call. Refer to the Treatment System Process Flow Chart for more facility detail.

In 2012, a supervisory control and data acquisition (SCADA) system installed to allow for continuous monitoring and recording. It includes alarming, enhanced operator control of the waterworks, and increased security features.



### ***Water Storage and Pumping Capabilities***

There is a 795 m<sup>3</sup> (175,000 IMPG) in-ground storage reservoir within the distribution system located approximately 700 meters (m) northwest of the Pump-house.

### ***Emergency Power***

Stand-by power is provided by an on-site diesel generator with an automatic transfer switch. In the event of a power outage in the area, the diesel generator automatically starts, providing continuous power to the Pump-house.

### ***Distribution System***

The Mattawa DWS is categorized as a Large Municipal Residential Drinking Water System and serves an estimated population of 2150 residents. The system has approximately 1,050 service connections to residential and commercial consumers. There is approximately 20,000 m of various sized cast iron, ductile iron and polyvinyl chloride piping. There are 117 fire hydrants in the distribution system.

## **3.0 List of Water Treatment Chemicals Used Over the Reporting Period**

The following chemicals used in the treatment process at the Mattawa Water Treatment Plant.

- Sodium hypochlorite – Secondary Disinfection

## **4.0 Significant Expenses Incurred in the Drinking Water System**

OCWA is committed to maintaining the assets of the drinking water system and maintains a program of scheduled inspection and maintenance activities using a computerized Work Management System (WMS). OCWA implemented a new Workplace Management System (Maximo) in 2023, which better maintains and optimizes facility assets. All routine maintenance activities conducted at the water treatment plant accomplished in 2024.

Significant expenses incurred in the drinking water system include:

- Repaired 2 inch water line inside Water Treatment Plant that was leaking.
- New Trojan Optiview UV analyzer installed and operational.
- Generator that powers the wellhouse and main sewage lift station failed. Throttle body controller was rush ordered. Emergency repairs did not correct the problem. Ran off of the reservoir during scheduled hydro outage.

## **5.0 Drinking Water System Highlights**

- The Ministry of the Environment, Conservation and Parks (MECP) performed their last annual inspection on February 14, 2024. The inspection included a physical assessment of the Mattawa Water Treatment Plant and a document review. The inspection report identified one non-compliance issue that has been resolved. Final inspection rating of 98.96% (discussed in last year's annual report).

## Mattawa Drinking Water System – 2024 Annual/Summary Report

- SAI Global conducted an off-site audit prior to the onsite Re-Accreditation of the Mattawa Drinking Water System's Quality and Environmental Management System (QEMS) on June 11, 2024. One opportunity for improvement (OFI) identified and resolved. The system and processes associated with the QEMS were evaluated on September 20, 2024 to ensure implementation of the Operational Plan and procedures and conformance to the Drinking Water Quality Management Standard version 2.0. Two OFIs identified and resolved. Re-accreditation achieved on June 21, 2023.

### 6.0 Details on Notices of Adverse Test Results and Other Problems Reported to & Submitted to the Spills Action Center

Based on information kept on record by OCWA, the Mattawa Drinking Water System had zero adverse water quality incidents reported to the MOE's Spills Action Centre (MOE SAC).

### 7.0 Microbiological Testing Performed During the Reporting Period

#### Summary of Microbiological Data

Sample Type	# of Samples	Range of <i>E. coli</i> Results (min to max)	Range of Total Coliform Results (min to max)	# of HPC Samples	Range of HPC Results (min to max)
Raw (Well No. 1)	54	0 to 0	0 to 2	0	N/A
Raw (Well No. 2)	54	0 to 0	0 to 10	0	N/A
Treated	54	0 to 0	0 to 0	54	0 to 6
Distribution	162	0 to 0	0 to 0	55	0 to 2

Maximum Allowable Concentration (MAC) for *E. coli* = 0 Counts/100 mL

MAC for Total Coliforms = 0 Counts/100 mL

"<" denotes less than the laboratory's method detection limit.

**Notes:** One microbiological sample is collected and tested each week from the raw (each well) and treated water supply. A total of three microbiological samples are collected and tested each week from the Mattawa distribution system.

Refer to *Appendix A* for a monthly summary of microbiological test results.

### 8.0 Operational Testing Performed During the Reporting Period

#### Summary of Raw Water Turbidity Data

Parameter	# of Samples	Range of Results (min to max)	Unit of Measure
Turbidity (Well No. 1)	12	0.24 to 0.35	NTU
Turbidity (Well No. 2)	12	0.22 to 0.30	

**Summary of Chlorine Residual Data in the Distribution System**

Parameter	No. of Samples	Range of Results (min to max)	Unit of Measure	Standard
Free Chlorine	361	0.2 to 1.65	mg/L	0.05

**Note:** A total of seven operational checks for chlorine residual in the distribution system are collected each week. Four (4) samples are tested one day and three (3) on a second day. The sample sets are collected at least 48-hours apart and samples collected on the same day are from different locations.

Refer to *Appendix B* for a monthly summary of the above operational data.

**Summary of Nitrate & Nitrite Data** (sampled at the water treatment plant)

Date of Sample	Nitrate Result Value	Nitrite Result Value	Unit of Measure	Exceedance
January 30	1.75	< 0.003	mg/L	No
April 10	1.58	< 0.003	mg/L	No
July 24	1.75	< 0.003	mg/L	No
October 10	1.67	< 0.003	mg/L	No

Maximum Allowable Concentration (MAC) for Nitrate = 10 mg/L  
MAC for Nitrite = 1 mg/L

**Summary of Total Trihalomethane Data** (sampled in the distribution system)

Date of Sample	Result Value	Unit of Measure	Running Average	Exceedance
January 30	0.004	mg/L	Q1 = 0.004	No
April 10	0.003		Q2 = 0.004	
July 24	0.005		Q3 = 0.004	
October 10	0.0047		Q4 = 0.004	

Maximum Allowable Concentration (MAC) for Total Trihalomethanes = 0.100 mg/L (Four Quarter Running Average)

**Summary of Total Haloacetic Acids Data** (sampled in the distribution system)

Date of Sample	Result Value	Unit of Measure	Running Average	Exceedance
January 30	< 0.005	mg/L	Q1 = 0.048	No
April 10	< 0.005		Q2 = 0.053	
July 24	< 0.0053		Q3 = 0.053	
October 10	< 0.0053		Q4 = 0.053	

Maximum Allowable Concentration (MAC) for Total Haloacetic Acids = 0.080 mg/L (Four Quarter Running Average)

**Summary of Most Recent Lead Data under Schedule 15.1**

(applicable to the following drinking water systems; large municipal residential systems, small, municipal residential systems, and non-municipal year-round residential systems)

The Mattawa DWS was eligible to follow the “Exemption from Plumbing Sampling” as described in section 15.1-5(9) and 15.1-5(10) of Schedule 15.1 of Ontario Regulation 170/03. The exemption applies to a drinking water system if, in two consecutive periods at reduced sampling, not more than 10% of all samples from plumbing exceed the maximum allowable concentration (MAC) of 10 ug/L or 0.01 mg/L for lead. As such, the system was required to

## Mattawa Drinking Water System – 2024 Annual/Summary Report

test for total alkalinity and pH in one distribution sample collected during the periods of December 15 to April 15 (winter period) and June 15 to October 15 (summer period). This testing is required in every 12-month period with lead testing in every third 12-month period. The Town of Mattawa has been sampling lead every term. Two rounds of lead, alkalinity and pH testing were carried out on April 10<sup>th</sup> and October 10<sup>th</sup> of 2024. Results are summarized in the table below.

### ***Summary of Lead, pH & Alkalinity Data (sampled in the distribution system)***

Date of Sample	# of Samples	Sample Location	Lead (ug/L)	Field pH	Alkalinity (mg/L)
April 10	1	Hydrant at 8 <sup>th</sup> and Rankin	0.04	7.49	45
April 10	1	Hydrant at Waterfront	1.93	7.45	43
October 10	1	Hydrant at 1 <sup>st</sup> and Bissett St.	0.06	7.16	43
October 10	1	Mattawan & Gorman Hydrant	0.12	7.20	45

### ***Most Recent Schedule 23 Inorganic Data Tested at the Water Treatment Plant***

Parameter	Result Value	Unit of Measure	Standard	Exceedance
Antimony	<0.0005	mg/L	0.006	No
Arsenic	<0.001	mg/L	0.01	No
Barium	0.03	mg/L	1	No
Boron	0.02	mg/L	5	No
Cadmium	<0.0001	mg/L	0.005	No
Chromium	<0.001	mg/L	0.05	No
Mercury	<0.0001	mg/L	0.001	No
Selenium	<0.001	mg/L	0.01	No
Uranium	<0.001	mg/L	0.02	No

**Note:** Sample required every 36 months (sample date = October 10, 2024). Next sampling scheduled for October 2027.

## Mattawa Drinking Water System – 2024 Annual/Summary Report

### ***Most Recent Schedule 24 Organic Data Tested at the Water Treatment Plant***

Treated Water	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Number of Exceedances	
				MAC	1/2 MAC
1,1-Dichloroethylene (ug/L)-TW	2024/10/10	< MDL 0.33	14	No	No
1,2-Dichlorobenzene (ug/L)-TW	2024/10/10	< MDL 0.41	200	No	No
1,2-Dichloroethane (ug/L)-TW	2024/10/10	< MDL 0.35	5	No	No
1,4-Dichlorobenzene (ug/L)-TW	2024/10/10	< MDL 0.36	5	No	No
2,3,4,6-Tetrachlorophenol (ug/L)-TW	2024/10/10	< MDL 0.2	100	No	No
2,4,6-Trichlorophenol (ug/L)-TW	2024/10/10	< MDL 0.25	5	No	No
2,4-Dichlorophenol (ug/L)-TW	2024/10/10	< MDL 0.15	900	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L)-TW	2024/10/10	< MDL 0.19	100	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (ug/L)-TW	2024/10/10	< MDL 0.12	100	No	No
Alachlor (ug/L) -TW	2024/10/10	< MDL 0.02	5	No	No
Atrazine + N-dealkylated metabolites (ug/L)-TW	2024/10/10	< MDL 0.01	5	No	No
Azinphos-methyl (ug/L)-TW	2024/10/10	< MDL 0.05	20	No	No
Benzene (ug/L)-TW	2024/10/10	< MDL 0.32	1	No	No
Benzo(a)pyrene (ug/L)-TW	2024/10/10	< MDL 0.004	0.01	No	No
Bromoxynil (ug/L)-TW	2024/10/10	< MDL 0.33	5	No	No
Carbaryl (ug/L)-TW	2024/10/10	< MDL 0.05	90	No	No
Carbofuran (ug/L) -TW	2024/10/10	< MDL 0.01	90	No	No
Carbon Tetrachloride (ug/L) -TW	2024/10/10	< MDL 0.17	2	No	No
Chlorpyrifos (ug/L) -TW	2024/10/10	< MDL 0.02	90	No	No
Diazinon (ug/L)-TW	2024/10/10	< MDL 0.02	20	No	No
Dicamba (ug/L)-TW	2024/10/10	< MDL 0.2	120	No	No
Dichloromethane (Methylene Chloride) (ug/L)-TW	2024/10/10	< MDL 0.35	50	No	No
Diclofop-methyl (ug/L)-TW	2024/10/10	< MDL 0.4	9	No	No
Dimethoate (ug/L)-TW	2024/10/10	< MDL 0.06	20	No	No
Diquat (ug/L)-TW	2024/10/10	< MDL 1	70	No	No
Diuron (ug/L)-TW	2024/10/10	< MDL 0.03	150	No	No
Glyphosate (ug/L)-TW	2024/10/10	< MDL 1	280	No	No
Malathion (ug/L)-TW	2024/10/10	< MDL 0.02	190	No	No
Metolachlor (ug/L)-TW	2024/10/10	< MDL 0.01	50	No	No
Metribuzin (ug/L)-TW	2024/10/10	< MDL 0.02	80	No	No
Monochlorobenzene (Chlorobenzene) (ug/L)-TW	2024/10/10	< MDL 0.3	80	No	No
Paraquat (ug/L)-TW	2024/10/10	< MDL 1	10	No	No
PCB (ug/L)-TW	2024/10/10	< MDL 0.04	3	No	No
Pentachlorophenol (ug/L)-TW	2024/10/10	< MDL 0.15	60	No	No
Phorate (ug/L)-TW	2024/10/10	< MDL 0.01	2	No	No
Picloram (ug/L)-TW	2024/10/10	< MDL 1	190	No	No
Prometryne (ug/L)-TW	2024/10/10	< MDL 0.03	1	No	No
Simazine (ug/L)-TW	2024/10/10	< MDL 0.01	10	No	No
Terbufos (ug/L)-TW	2024/10/10	< MDL 0.01	1	No	No
Tetrachloroethylene (ug/L)-TW	2024/10/10	< MDL 0.35	10	No	No
Triallate (ug/L) -TW	2024/10/10	< MDL 0.01	230	No	No
Trichloroethylene (ug/L)-TW	2024/10/10	< MDL 0.44	5	No	No
Trifluralin (ug/L)-TW	2024/10/10	< MDL 0.02	45	No	No
Vinyl Chloride (ug/L)-TW	2024/10/10	< MDL 0.17	1	No	No

**Note:** Sample required every 36 months (sample date = *October 10, 2024*). Next sampling scheduled for October 2027.



***Inorganic or Organic Test Results that Exceeded Half the Standard Prescribed in Schedule 2 of the Ontario Drinking Water Quality Standards.***

No inorganic or organic parameter(s) listed in Schedule 23 and 24 of Ontario Regulation 170/03 exceeded half the standard found in Schedule 2 of the Ontario Drinking Water Standard (O. Reg. 169/03) during the reporting period.

***Most Recent Sodium Data Sampled at the Water Treatment Plant***

Date of Sample	# of Samples	Result Value	Unit of Measure	Standard	Exceedance
January 24, 2023	1	14.4	mg/L	20	No
January 16, 2018	1	13			No

**Note:** Sample required every 60 months. Next sampling scheduled for January 2028.

***Most Recent Fluoride Data Sampled at the Water Treatment Plant***

Date of Sample	# of Samples	Result Value	Unit of Measure	Standard	Exceedance
February 15, 2023	1	<0.10	mg/L	1.5	No
January 16, 2018	1	<0.15			No

**Note:** Sample required every 60 months. Next sampling scheduled for January 2028. Please note: sample collected on January 24, 2023; however, lab lost sample in transit to sub lab. Resample collected February 15, 2023.

***Summary of Additional Testing Performed in Accordance with a Legal Instrument.***

1. Schedule C, Section 1.6 of Municipal Drinking Water Licence #195-101 requires the UV disinfection system to maintain a continuous pass-through UV dose of at least 40 millijoules per square centimeter (mJ/cm<sup>2</sup>) throughout the life span of the UV lamps.

A primary disinfection system consisting of two (2) parallel UV reactors (duty and standby), each rated to provide dosage of 40 mJ/cm<sup>2</sup> at a peak flow of 76 L/s, equipped with automatic switchover controls. Ultra-Violet Light Transmittance (UVT) is continuously monitored. If the duty reactor fails the following would occur:

- the low lift pump would shut off
- the (failed) duty UV reactor's water inlet valve would close
- an alarm would be generated and sent through the emergency call-out system to alert operators of the failure of the duty reactor
- the standby UV reactor would switchover and begin producing water

Table 4 of the licence also requires the following parameters related to the UV disinfection system to be continuously monitored and recorded every four (4) hours:

***UV Intensity(Calculated UV Dose)*** Measured continuously by the UV system. UV intensity is monitored by each individual unit's control module and should the light intensity of the unit fall



outside the specified range, the unit will automatically shut down and a standby unit will be activated. Such an event will be recorded by the UV control system.

**Flow Rate** The maximum flow rate through each of the units is 76 L/s (see Schedule A of DWWP 195-201) which is continuously measured by the raw/treated water flow meters. One flow meter measures flow from both wells, while the other flow meter only measures Well 2 flows. Each UV unit is equipped with a flow control valve and an electronically activated water shut-off valve which will automatically close in the event of a UV equipment malfunction, loss of power or ceases to provide an appropriate level of disinfection.

**UV Transmittance** UVT is continuously monitored.

**Lamp Status** Monitored by each unit's control module. Should the lamp status fail, the unit will automatically shut down and a standby unit will be activated. Such an event will be recorded by the UV control system.



Mattawa Drinking Water System

Schedule 22

# 2024 SUMMARY REPORT

## FOR MUNICIPALITIES

## Schedule 22 - SUMMARY REPORTS FOR MUNICIPALITIES

---

### 1.0 Introduction

<b>Drinking-Water System Name:</b>	<b>MATTAWA DRINKING WATER SYSTEM</b>
<b>Municipal Drinking Water Licence (MDWL) No.:</b>	195-101-4 (issued December 3, 2021)
<b>Drinking Water Work Permit (DWWP) No.:</b>	195-201-3 (issued December 3, 2021)
<b>Permit to Take Water (PTTW) No.:</b>	1546-9GHPLM (issued February 27, 2014)
<b>Period being reported:</b>	January 1, 2024 to December 31, 2024

### 2.0 Requirements the System Failed to Meet

The last MECP inspection report dated February 14, 2024 had one non-compliance issue, identified in last year's annual report. Final inspection rating was 98.96%.

According to information kept on record by OCWA; there were zero non-compliance issues that occurred during 2024.

### 3.0 Summary of Quantities and Flow Rates

#### ***Flow Monitoring***

MDWL No. 195-101 requires the owner to install a sufficient number of flow measuring devices to permit the continuous measurement and recording of:

- the flow rate and daily volume of treated water that flows from the treatment subsystem the distribution system, and
- the flow rate and daily volume of water that flows into the treatment subsystem.

The flow monitoring equipment identified in the MDWL is present and operating as required. The flow meter is calibrated on an annual basis as specified in the manufacturers' instructions.

#### ***Water Usage***

The following water usage tables summarize the quantities and flow rates of water taken and produced during the 2024 reporting period, including total monthly volumes, average monthly volumes, maximum monthly volumes, and maximum flow rates.

## Mattawa Drinking Water System – 2024 Annual/Summary Report

### Raw Water

#### 2024 - Monthly Summary of Water Takings from the Source (Well #1)

Regulated by Permit to Take Water (PTTW) #1546-9GHPLM, issued February 27, 2014

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year to Date
Total Volume (m <sup>3</sup> )	46279	41671	31551	26486	28758	39418	41563	43070	41144	45557	35253	13646	434394
Average Volume (m <sup>3</sup> /d)	1493	1437	1018	883	928	1314	1385	1389	1371	1470	1175	440	1192
Maximum Volume (m <sup>3</sup> /d)	1795	1530	1762	1104	1300	1684	1780	1772	1693	2106	1482	1242	2106
PTTW - Maximum Allowable Volume (m <sup>3</sup> /day)	4582	4582	4582	4582	4582	4582	4582	4582	4582	4582	4582	4582	4582
Maximum Flow Rate (L/min)	4516	4730	5395	4111	3968	4108	4398	4005	4203	4360	4417	3842	5395
PTTW - Maximum Allowable Flow Rate (L/min)	3183	3183	3183	3183	3183	3183	3183	3183	3183	3183	3183	3183	3183

Well #1 experiences false instantaneous peaks.

#### 2024 - Monthly Summary of Water Takings from the Source (Well #2)

Regulated by Permit to Take Water (PTTW) #1546-9GHPLM, issued February 27, 2014

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year to Date
Total Volume (m <sup>3</sup> )	3649	4396	3981	4955	7346	2086	3740	2545	3436	4337	11800	31007	83279
Average Volume (m <sup>3</sup> /d)	118	152	128	165	237	70	121	82	115	140	393	1000	227
Maximum Volume (m <sup>3</sup> /d)	401	421	525	420	743	558	915	403	410	402	1574	1534	1574
PTTW - Maximum Allowable Volume (m <sup>3</sup> /day)	1964	1964	1964	1964	1964	1964	1964	1964	1964	1964	1964	1964	1964
Maximum Flow Rate (L/min)	1272	1273	1255	1324	1265	1823	1301	1262	1330	1276	1259	1231	1823
PTTW - Maximum Allowable Flow Rate (L/min)	1364	1364	1364	1364	1364	1364	1364	1364	1364	1364	1364	1364	1364

Well #2 experiences false instantaneous peaks

#### 2024 - Monthly Summary of Combined Water Takings from the Source (Well #1 and Well #2)

Regulated by Permit to Take Water (PTTW) #1546-9GHPLM, issued February 27, 2014

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year to Date
Total Volume (m <sup>3</sup> )	49928	46067	35532	31441	36104	41503	45138	45615	44580	49894	47053	47053	519908
Average Volume (m <sup>3</sup> /d)	1611	1589	1146	1048	1165	1383	1461	1471	1486	1609	1568	1440	1415
Maximum Volume (m <sup>3</sup> /d)	1821	1748	1762	1415	1461	1871	1780	1799	1767	2118	1933	1594	2118
PTTW - Maximum Allowable Volume (m <sup>3</sup> /day)	6546	6546	6546	6546	6546	6546	6546	6546	6546	6546	6546	6546	6546

The system's Permit to Take Water #1546-9GHPLM, allows the Municipality to withdraw water at the following rates:

Well No. 1: 4582.08 m<sup>3</sup>/day / 3183 L/minute

Well No. 2: 1964.16 m<sup>3</sup>/day / 1364 L/minute

Total Combined Daily Volume: 6546.24 m<sup>3</sup>/day

The system's Permit to Take Water #1546-9GHPLM allows the municipality to withdraw a maximum volume of 4582.08 m<sup>3</sup> from Well No. 1 and 1964.16 m<sup>3</sup> from Well No. 2 each day with a maximum of 6546.24 m<sup>3</sup>/d combined. A review of the raw water flow data indicates that the system never exceeded this allowable limit having a maximum volume of 2118 m<sup>3</sup> in October 2024. The Permit also allows a maximum flow rate of 3183 L/minute for Well No. 1 and 1364 L/minute for Well No. 2. Well 1 experiences false peaks on start-up, having a

## Mattawa Drinking Water System – 2024 Annual/Summary Report

maximum recorded flow of 5395 L/minute in March 2024 for Well 1 and 1843 L/minute in June 2024 for Well 2.

### Treated Water

#### 2024 - Monthly Summary of Treated Water Supplied to the Distribution System

Regulated by Municipal Drinking Water Licence (MDWL) #195-101 - Issue 4, issued December 3, 2021

	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Year to Date
Total Volume (m <sup>3</sup> )	49928	46067	35532	31441	36104	41503	45138	45615	44580	49894	47053	47053	519908
Average Volume (m <sup>3</sup> /d)	1611	1589	1146	1048	1165	1383	1461	1471	1486	1609	1568	1440	1415
Maximum Volume (m <sup>3</sup> /d)	1821	1748	1762	1415	1461	1871	1780	1799	1767	2118	1933	1594	2118
MDWL - Rated Capacity (m <sup>3</sup> /day)	6540	6540	6540	6540	6540	6540	6540	6540	6540	6540	6540	6540	6540


Schedule C, Section 1.1 of MDWL No. 195-101 states that the maximum daily volume of treated water that flows from the treatment subsystem to the distribution system shall not exceed a maximum flow rate of 6540 m<sup>3</sup>/day. The Mattawa DWS complied with this limit having a recorded maximum volume of 2118 m<sup>3</sup> in October 2024, which is 32.4% of the rated capacity.

Figure 1 compares the average and maximum flow rates into the distribution system to the rated capacity of the system identified in the MDWL. This information enables the Owner to assess the system's existing and future planned water usage needs.

#### **Comparison of the Flow Summary to the Systems Licence & Permit**

Rated Capacity of the Plant (MDWL)	6540 m <sup>3</sup> /day	
Average Daily Flow for 2024	1415 m <sup>3</sup> /day	21.6% of the rated capacity
Maximum Daily Flow for 2024	2118 m <sup>3</sup> /day	32.4% of the rated capacity
Total Treated Water Produced in 2024	519908 m <sup>3</sup>	

The Mattawa Water Treatment Plant is rated to produce 6540 cubic meters of water per day as specified in the system's Municipal Drinking Water Licence. The average daily flow was 1415 m<sup>3</sup> per day, which is 21.6% of the rated capacity. This information clearly shows that the plant is well within its rated capacity and is able to meet current demands of consumers.



## CONCLUSION

In 2024, according to information kept on record by OCWA, the Mattawa DWS provided safe and reliable drinking water to the community of Mattawa. The system complied with the regulatory requirements of the Safe Drinking Water Act and its Regulations and met the terms and conditions outlined in its site specific drinking water works permit and municipal drinking water licence. According to information kept on record by OCWA; there were zero non-compliance issues that occurred during 2024. Furthermore, the Mattawa DWS had zero adverse water quality incidents reported to the MOE's Spills Action Centre.





# **APPENDIX A**

## Monthly Summary of Microbiological Test Results

Customized Monthly Report

From 01/01/2024 to 12/31/2024

Facility Name: MATTAWA DRINKING WATER SYSTEM  
Receiver:

Facility Org Number: 1517  
Facility Owner:  
Service Population: 2150

Works: 210001905  
Facility Classification:  
Total Design Capacity: 6540 m3/day



		2024															
DW		Jan 2024	Feb 2024	Mar 2024	Apr 2024	May 2024	Jun 2024	Jul 2024	Aug 2024	Sep 2024	Oct 2024	Nov 2024	Dec 2024	Total	Avg	Max	Min
	E. Coli - cfu/100mL																
	Count	15.00	12.00	12.00	15.00	15.00	12.00	15.00	12.00	12.00	15.00	12.00	15.00	162.00			
	Lab Count	15.00	12.00	12.00	15.00	15.00	12.00	15.00	12.00	12.00	15.00	12.00	15.00	162.00			
	Lab Month.Max	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	
	Lab Month.Mean	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00		
	Lab Month.Min	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00
	HPC - cfu/mL																
	Count	3.00	3.00	3.00	6.00	9.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	55.00			
	Lab Count	3.00	3.00	3.00	6.00	9.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	55.00			
	Lab Month.Max	1.00	0.00	0.00	1.00	0.00	0.00	1.00	2.00	0.00	1.00	0.00	2.00			2.00	
	Lab Month.Mean	0.33	0.00	0.00	0.17	0.00	0.00	0.20	0.50	0.00	0.20	0.00	0.40		0.15		
	Lab Month.Min	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00
	Total Coliform: TC - cfu/100mL																
	Count	15.00	12.00	12.00	15.00	15.00	12.00	15.00	12.00	12.00	15.00	12.00	15.00	162.00			
	Lab Count	15.00	12.00	12.00	15.00	15.00	12.00	15.00	12.00	12.00	15.00	12.00	15.00	162.00			
	Lab Month.Max	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	
	Lab Month.Mean	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00		
	Lab Month.Min	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00
														2024			
Well #1		Jan 2024	Feb 2024	Mar 2024	Apr 2024	May 2024	Jun 2024	Jul 2024	Aug 2024	Sep 2024	Oct 2024	Nov 2024	Dec 2024	Total	Avg	Max	Min
	E. Coli: EC - cfu/100mL																
	Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00			
	Lab Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00			
	Lab Month.Max	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00	
	Lab Month.Mean	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00		
	Lab Month.Min	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00
	Total Coliform: TC - cfu/100mL																
	Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00			
	Lab Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00			
	Lab Month.Max	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.00	1.00			2.00	
	Lab Month.Mean	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.50	0.20		0.06		
	Lab Month.Min	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00

Customized Monthly Report

From 01/01/2024 to 12/31/2024

Facility Name: MATTAWA DRINKING WATER SYSTEM  
Receiver:

Facility Org Number: 1517  
Facility Owner:  
Service Population: 2150

Works: 210001905  
Facility Classification:  
Total Design Capacity: 6540 m3/day



																		2024			
Well #2		Jan 2024	Feb 2024	Mar 2024	Apr 2024	May 2024	Jun 2024	Jul 2024	Aug 2024	Sep 2024	Oct 2024	Nov 2024	Dec 2024	Total	Avg	Max	Min				
E. Coli: EC - cfu/100mL																					
	Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00							
	Lab Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00							
	Lab Month.Max	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00					
	Lab Month.Mean	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00						
	Lab Month.Min	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00				
Total Coliform: TC - cfu/100mL																					
	Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00							
	Lab Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00							
	Lab Month.Max	0.00	0.00	0.00	2.00	0.00	0.00	0.00	0.00	0.00	0.00	10.00	0.00			10.00					
	Lab Month.Mean	0.00	0.00	0.00	0.60	0.00	0.00	0.00	0.00	0.00	0.00	2.50	0.00		0.24						
	Lab Month.Min	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00				
																		2024			
TW		Jan 2024	Feb 2024	Mar 2024	Apr 2024	May 2024	Jun 2024	Jul 2024	Aug 2024	Sep 2024	Oct 2024	Nov 2024	Dec 2024	Total	Avg	Max	Min				
E. Coli: EC - cfu/100mL																					
	Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00							
	Lab Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00							
	Lab Month.Max	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00					
	Lab Month.Mean	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00						
	Lab Month.Min	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00				
HPC - cfu/mL																					
	Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00							
	Lab Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00							
	Lab Month.Max	0.00	0.00	0.00	2.00	6.00	1.00	0.00	6.00	1.00	0.00	3.00	1.00			6.00					
	Lab Month.Mean	0.00	0.00	0.00	0.60	1.20	0.50	0.00	1.50	0.25	0.00	1.25	0.20		0.44						
	Lab Month.Min	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00				
Total Coliform: TC - cfu/100mL																					
	Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00							
	Lab Count	5.00	4.00	4.00	5.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	5.00	54.00							
	Lab Month.Max	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00			0.00					
	Lab Month.Mean	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00		0.00						
	Lab Month.Min	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00				0.00				



# **APPENDIX B**

## Monthly Summary of Operational Data

Customized Monthly Report

From 01/01/2024 to 12/31/2024

Facility Name: MATTAWA DRINKING WATER SYSTEM  
Receiver:

Facility Org Number: 1517  
Facility Owner:  
Service Population: 2150

Works: 210001905  
Facility Classification:  
Total Design Capacity: 6540 m3/day



														2024			
DW		Jan 2024	Feb 2024	Mar 2024	Apr 2024	May 2024	Jun 2024	Jul 2024	Aug 2024	Sep 2024	Oct 2024	Nov 2024	Dec 2024	Total	Avg	Max	Min
	CI Residual: Free DW1 - mg/L																
	Count	9.00	8.00	9.00	9.00	9.00	8.00	9.00	9.00	8.00	8.00	8.00	9.00	103.00			
	IH Edited Count	9.00	8.00	9.00	9.00	9.00	8.00	9.00	9.00	8.00	8.00	8.00	9.00	103.00			
	IH Month.Max	0.51	0.71	0.74	0.95	0.89	0.72	0.89	0.81	0.84	0.94	1.65	0.71			1.65	
	IH Month.Mean	0.42	0.54	0.58	0.65	0.62	0.49	0.60	0.49	0.66	0.73	0.99	0.62		0.61		
	IH Month.Min	0.31	0.31	0.31	0.34	0.31	0.29	0.31	0.29	0.40	0.45	0.49	0.48				0.29
	CI Residual: Free DW2 - mg/L																
	Count	9.00	8.00	9.00	9.00	9.00	8.00	9.00	9.00	8.00	8.00	8.00	9.00	103.00			
	IH Edited Count	9.00	8.00	9.00	9.00	9.00	8.00	9.00	9.00	8.00	8.00	8.00	9.00	103.00			
	IH Month.Max	0.65	0.77	0.71	1.44	0.78	0.71	0.81	0.69	0.79	0.81	0.81	0.79			1.44	
	IH Month.Mean	0.51	0.50	0.48	0.63	0.57	0.56	0.59	0.48	0.61	0.71	0.69	0.60		0.58		
	IH Month.Min	0.35	0.31	0.32	0.25	0.31	0.30	0.31	0.29	0.29	0.59	0.50	0.44				0.25
	CI Residual: Free DW3 - mg/L																
	Count	9.00	8.00	9.00	9.00	9.00	8.00	9.00	9.00	8.00	8.00	8.00	9.00	103.00			
	IH Edited Count	9.00	8.00	9.00	9.00	9.00	8.00	9.00	9.00	8.00	8.00	8.00	9.00	103.00			
	IH Month.Max	0.67	0.79	0.87	1.18	0.84	0.70	0.77	0.78	0.77	0.64	0.88	0.77			1.18	
	IH Month.Mean	0.53	0.55	0.54	0.71	0.59	0.49	0.53	0.49	0.58	0.52	0.64	0.58		0.56		
	IH Month.Min	0.31	0.38	0.39	0.36	0.31	0.29	0.33	0.30	0.39	0.31	0.48	0.38				0.29
	CI Residual: Free DW4 - mg/L																
	Count	5.00	4.00	4.00	5.00	4.00	4.00	5.00	4.00	4.00	4.00	4.00	5.00	52.00			
	IH Edited Count	5.00	4.00	4.00	5.00	4.00	4.00	5.00	4.00	4.00	4.00	4.00	5.00	52.00			
	IH Month.Max	0.58	0.61	0.51	0.61	0.64	0.60	0.80	0.65	0.59	0.71	0.80	0.81			0.81	
	IH Month.Mean	0.51	0.56	0.46	0.54	0.55	0.54	0.60	0.51	0.53	0.58	0.65	0.67		0.56		
	IH Month.Min	0.47	0.54	0.41	0.50	0.49	0.48	0.49	0.44	0.48	0.29	0.27	0.59				0.27
														2024			
Well #1		Jan 2024	Feb 2024	Mar 2024	Apr 2024	May 2024	Jun 2024	Jul 2024	Aug 2024	Sep 2024	Oct 2024	Nov 2024	Dec 2024	Total	Avg	Max	Min
	Turbidity - NTU																
	Count	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00			
	IH Edited Count	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00			
	IH Month.Mean	0.26	0.24	0.24	0.27	0.30	0.27	0.26	0.28	0.27	0.35	0.31	0.31		0.28		
														2024			
Well #2		Jan 2024	Feb 2024	Mar 2024	Apr 2024	May 2024	Jun 2024	Jul 2024	Aug 2024	Sep 2024	Oct 2024	Nov 2024	Dec 2024	Total	Avg	Max	Min
	Turbidity - NTU																
	Count	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00			
	IH Edited Count	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00			
	IH Month.Mean	0.27	0.27	0.28	0.22	0.28		0.26	0.25	0.29	0.28	0.30	0.29		0.28		
	IH Month.Min	0.27	0.27	0.28	0.22	0.28	0.28	0.26	0.25	0.29	0.28	0.30	0.29				0.22