



Building Division
Town Hall, P.O. Box 390
160 Water Street
Mattawa, Ontario
Canada, P0H 1V0
705-744-5611

Building a Deck Information Guide and Process

When is a building permit required for a deck?

- If the deck is new or being replaced
- A permit is also required if structural renovations will be made to an existing deck.

Drawing requirements for a building permit application

1. A copy of the property survey or site plan of your lot.
 - a. Please draw on location of deck with dimensions to lot lines
2. Deck drawings (Building centre drawings or hand drawn to scale and dimensioned)
 - a. Plan view showing posts, floor joists, beams, stairs, landings
 - b. Side view showing height of deck and guard

*ask for our deck design details for assistance

Guards/Railings (for decks 24" or higher)

The Ontario Building Code permits the installation of wood guards/railings. Should you plan on installing anything other than a wood guard/railing, please submit a copy of the Pre-Engineered guard/railing details with your building permit application. Typically you can receive this package of details from the supplier.

NOTE: Hollow plastic or vinyl guards/railing are not permitted

Approved Decking Materials (for decks 24" or higher)

- 5/4" wood decking
- CWS Composite Decking
- Duradek boards
- Brite Composite Decking
- Nexwood Composite Decking
- Trex Wood-Polymer Composite Decking
- Eon Composite Decking System
- Baleboard Poly Decking
- FORMADECK vinyl deck boards
- NCP Euroboard, Enviroboard, Northern Lite Decking
- Gorilla Deck PVC Deck Boards

Where to apply for a building permit

Apply online at www.mattawa.ca or bring all required drawings to the Town Hall. Town Hall is located at 160 Water St , Mattawa, Ontario.

Cost of building permit

The cost of the permit is determined by price of job, we accept cash, cheque and debit as methods of payment. This includes the review of drawings, the building permit and building inspections. Our office hours are Monday to Friday, 9:00am - 5:00pm.

Time

Once a complete permit application is made the permit will be reviewed within a maximum of 10 business days.

Required Building Inspections

Building inspections are booked through our automated phone system. Please schedule in advance, same day service is only available when booked before 8:00am the day of the inspection. Required inspections include;

- Excavation/Footing inspection - Once the holes have been dug, but prior to concrete being poured
- Structural Wood Frame inspection - Once the framing is complete (posts, beams, joists)
- Final Building inspection - When the deck and guard/railing are complete

Important Numbers to know

- Ontario One Call (natural gas, sewer/ water lines, Hydro One, Cable and Bell locates) 1-800-400-2255
- Electrical Safety Authority: 1-877-ESA-SAFE (1-877-372-7233)

Any Questions?

Phone: 705-744-5611

Email: wayne.chaput@mattawa.ca

Web: www.mattawa.ca



Building
Division


Deck Layout and Span Tables

DATE:
JANUARY 2013

SCALE:
NOT TO SCALE

DRAWING NO.:

9-3a



Deck Layout

**All decking is to be 5/4 x 6 wood material or approved equal

Maximum 2-Ply Beam Length				
Supported Joist Length	2 x 8	2 x 10	2 x 12	
4'-0"	11'-7"	14'-10"	17'-4"	
6'-0"	9'-10"	12'-1"	14'-0"	
8'-0"	8'-7"	10'-6"	12'-3"	
10'-0"	7'-8"	9'-4"	10'-8"	
Maximum 3-Ply Beam Length				
8'-0"	10'-8"	13'-0"	15'-1"	
10'-0"	9'-6"	11'-8"	13'-6"	

Maximum Floor Joist Length		
Joist Size	Max. Span	Max. Cantilever
2x8 @ 12" O.C.	12'-6"	20"
2x8 @ 16" O.C.	11'-9"	16"
2x8 @ 24" O.C.	11'-0"	14"
2x10 @ 12" O.C.	14'-6"	28"
2x10 @ 16" O.C.	13'-8"	24"
2x10 @ 24" O.C.	12'-10"	20"
2x12 @ 12" O.C.	16'-5"	28"
2x12 @ 16" O.C.	15'-6"	24"
2x12 @ 24" O.C.	14'-6"	20"



Deck Details

Guard, Post, Beam, Footing and Ledger Board

DATE:


JANUARY 2013

SCALE:

NOT TO SCALE

DRAWING NO.:

9-3b




NOTE: ANYTHING OTHER THAN A WOOD GUARD/RAILING, PLEASE SUBMIT A COPY OF THE PRE-ENGINEERED GAURD/RAILING DETAILS WITH YOUR BUILDING APPLICATION.

Option A

Option B


Guard Details




Post Detail

****SOLID BLOCKING REQUIRED FOR BEAMS @ 18" O.C.**

****ADDITIONAL LATERAL BRACING MAY BE REQUIRED. CONFIRM WITH BUILDING INSPECTOR @ FRAMING INSPECTION.**



Guard Post Detail



MINIMUM 3/8"Ø ANCHOR BOLTS @ 16" CENTERS
STAGGERED. ANCHOR BOLTS MUST BE INTO
WOOD FRAMING OR FOUNDATION WALL. DO
NOT SECURE INTO BRICK VENEER ALONE.

Ledger Board Detail



Building Division


Deck Elevations and Details

DATE:
JANUARY 2013

SCALE:
NOT TO SCALE

DRAWING NO.:

9-3c




Deck Elevation

Sonotube Sizes

Diameter	*Weight
8"Ø	1047 lbs
10"Ø	1635 lbs
12"Ø	2355 lbs
14"Ø	3207 lbs
16"Ø	4189 lbs

*Weight = (supported joist length each side of post x half beam length each side of post) x 40 lbs/SF

- 35" FOR DECKS 5'-11" OR LESS ABOVE GRADE
- 42" FOR DECKS GREATER THAN 5'-11" ABOVE GRADE.



Stair Detail

Stair Dimensions		
Type	Max.	Min.
Rise	7 7/8"	4 7/8"
Run	14"	8 1/4"
Tread	14"	9 1/4"

max 1" nosing

*Risers shall have a uniform height in any one flight of stairs.

*Treads shall have a uniform run and tread depth in any one flight of stairs.